



RECALL NOTICE

R. W. Beckett Corp. Announces a Recall Notice for Firomatic® 1/2" Female Pipe Thread (FPT) Fusible Safety Valve p/n 12130

REM Catalog # 2K249

Hazard: The stem may not travel far enough to properly seat and shut off the flow of fuel if exposed to trip point temperature.

Recalled Product: Firomatic® 1/2" FPT valve p/n 12130 as pictured above is affected. Suspect valves can be identified by the name 'Firomatic' cast into the body of the valve.

Remedy: Option 1 – Retrofit valve with retrofit kit part number 12130VR. 3 1/2" of clearance above the top of the valve stem will be required.
Option 2 – Replace valve or install an additional 12130 valve downstream of existing valve. Manual shut-off of existing valves is not affected.

For more information:
1-800-645-2876
www.beckettcorp.com

This recall is being conducted in cooperation with the U.S. Consumer Product Safety Commission.

Post until 4/1/2017